


DATA SHEET	6 ZONE CONVENTIONAL MODULAR TYPE FIRE ALARM PANEL WITH MANUAL ACTUATION MODULE	PART NO : IH046/Z6/MA6
-------------------	---	---------------------------

DP-5.8/10-335	DATE : FEB 2011	REVISION : 00	SCALE : N.T.S	SHEET : 1 OF 2	APPD. BY : DB
---------------	-----------------	---------------	---------------	----------------	---------------

INTRODUCTION :-

CONVENTIONAL FIRE ALARM PANEL WITH MODULAR TYPE ZONE CARD IS USED IN SENSING CONVENTIONAL SMOKE/HEAT/FLAME DETECTORS/MCP/SPARK DETECTOR. EACH ZONE IS PROVIDED WITH 24V DC OUTPUT (MAX.500mA). TO ACTUATE SOLENOID OR ANY OTHER DEVICES. MANUAL PUSH BUTTON MODULE IS PROVIDED TO ACTUATE FIRE ZONE MANUALLY.



LEGEND		
SL No.	SYMBOL	DESCRIPTION
01	AC	AC MODULE
02	DC	DC MODULE
03	CH	CHARGER MODULE
04	CN	CONTROL MODULE
05	Z1 to Z6	ZONE MODULE
06	MA	MANUAL ACTUATION MODULE
07	DS	DUMMY SHEET

NOTES: -

1. ALL DIMENSIONS ARE IN "mm" UNLESS OTHERWISE SPECIFIED.
2. TOLERANCE ON DIMENSION ± 3 mm, UNLESS OTHERWISE SPECIFIED.

TECHNICAL SPECIFICATION

01. PAINT	FIRE RED (POWDER COATING)	08. PRIMARY SOURCE	230V, 1PH, 50HZ AC SUPPLY
02. TYPE OF MOUNTING	WALL MOUNTING TYPE.	09. SECONDARY SOURCE	2 x 12V DC OF SUITABLE AMPS
03. CABLE BOTTOM ENTRY	$\phi 19$ mm KNOCK OUTS-28 Nos.	10. SIGNALING VOLTAGE TO DETECTORS	SMF BATTERY
04. OVER ALL DIMENSIONS	550 (L) x 300 (W) x 900 (H)	11. VOLTMETER	18-22V DC.
05. CONSTRUCTION OF PANEL	1.66mm (16 SWG) C.R. SHEET	12. AMMETER	0-50 V DC (SIZE-72 Sq.mm)
06. CONSTRUCTION OF DOOR	2mm (14 SWG) C.R. SHEET	13. PROTECTION CLASS	0-10 A DC (SIZE-72 Sq.mm)
07. WORKING VOLTAGE	24V DC		IP52

IMPORTANT:

AGNI CONTROLS RESERVES THE RIGHT TO CHANGE OR MODIFY WITHOUT PREVIOUS NOTICE ANY DATA OR SPECIFICATION DUE TO CHANGES OR MODIFICATION IN ORDER TO IMPROVE THE PRODUCTS / SYSTEM PRESENTED.



NO.1, 6TH STREET, Dr.SUBBARAYAN NAGAR,
KODAMBAKKAM, CHENNAI-600 024, INDIA.

PHONE : +91 44 2481 2420, FAX : +91 44 2481 2475,


E-MAIL : engineering@agnicontrols.com WEBSITE : www.balafire.com

**ISO 9001 - 2008
CERTIFIED BY
BUREAU VERITAS**

DATA SHEET	6 ZONE CONVENTIONAL MODULAR TYPE FIRE ALARM PANEL WITH MANUAL ACTUATION MODULE	PART NO : IH046/Z6/MA6
-------------------	---	---------------------------

DP-5.8/10-335	DATE : FEB 2011	REVISION : 00	SCALE : N.T.S	SHEET : 2 OF 2	APPD. BY : DB
---------------	-----------------	---------------	---------------	----------------	---------------

FRONT FACIA DETAIL (N.T.S)



IMPORTANT:

AGNI CONTROLS RESERVES THE RIGHT TO CHANGE OR MODIFY WITHOUT PREVIOUS NOTICE ANY DATA OR SPECIFICATION DUE TO CHANGES OR MODIFICATION IN ORDER TO IMPROVE THE PRODUCTS / SYSTEM PRESENTED.



NO.1, 6TH STREET, Dr.SUBBARAYAN NAGAR,
KODAMBAKKAM, CHENNAI-600 024, INDIA.
PHONE : +91 44 2481 2420, FAX : +91 44 2481 2475,
E-MAIL : engineering@agnicontrols.com WEBSITE : www.balafire.com

ISO 9001 - 2008
CERTIFIED BY
BUREAU VERITAS