

DATA SHEET

2C x 1.5 SQ. MM. FRLS. CU. ARMD. CABLE

PART NO :
B214-2C

DP-5.8/11-376

DATE : FEB 2011

REVISION : 00

SCALE : N.T.S

SHEET : 1 OF 1

APPD. BY : DB

TECHNICAL SPECIFICATION FOR 2C x 1.5 SQ. MM. FRLS. CU. ARMD. CABLE

STANDARD	:	IS : 1554 (PART - I)
NOMINAL CROSS SECTIONAL AREA	:	1.5 SQ. MM.
NOMINAL THICKNESS OF INSULATION	:	0.8 MM.
NOMINAL THICKNESS OF INNER SHEATH	:	0.3 MM.
NOMINAL DIA. OF ARMOUR STEEL WIRE	:	1.4 MM.
MAXIMUM THICKNESS OF OUTER SHEATH	:	1.24 MM.
OVERALL DIAMETER	:	12.5 MM (APPROX)
WEIGHT	:	320 KG / KM. (APPROX)

IMPORTANT:

AGNI CONTROLS RESERVES THE RIGHT TO CHANGE OR MODIFY WITHOUT PREVIOUS NOTICE ANY DATA OR SPECIFICATION DUE TO CHANGES OR MODIFICATION IN ORDER TO IMPROVE THE PRODUCTS / SYSTEM PRESENTED.



NO.1, 6TH STREET, Dr.SUBBARAYAN NAGAR,
KODAMBAKKAM, CHENNAI-600 024, INDIA.

PHONE : +91 44 2481 2420, FAX : +91 44 2481 2475,

E-MAIL : engineering@agnicontrols.com WEBSITE : www.balafire.com

ISO 9001 - 2008
CERTIFIED BY
BUREAU VERITAS